

VI-2 Status of Occupational Radiation Exposure Management at Commercial Reactor Facilities

- (1) Licensees for the construction of reactors, etc. are obligated to control the exposure levels of personnel engaged in radiation work not to exceed the exposure limit prescribed by the Nuclear Reactor Regulation Law.

This document has been compiled from the FY1988 "Report on Radiation Management, Etc.," as submitted by licensees for the construction of commercial reactor facilities in accordance with the Nuclear Reactor Regulation Law, and the "Report on Exposure Dose, Etc., of Radiation Workers," etc., in accordance with an administrative notification.

According to these reports, the records of occupational radiation exposure at commercial reactor facilities in FY1988 were lower than the limit at all nuclear plants.

For reference, the annual exposure records of personnel engaged in commercial reactor facilities since FY1979 are provided in the appendix.

[Reference] Individual exposure limits of personnel engaged in radiation work is 3 rems per three months.

- (2) The following are notes for the tables:

- 1) The "total" number of personnel engaged in radiation work is the sum of all numbers recorded at each nuclear facility. Therefore, workers who have worked at more than one facility are counted more than once.
- 2) The "total exposure dose" values for "employees" and "others" were rounded to the nearest whole number. For some data, the sum of "employees" and "others" does not correspond with the "total," which is an error arising from the calculation method described above.
- 3) The "average dose" values were rounded to two decimal places.
- 4) Reactors have been included in the "unit number of reactors" only after reaching the first critical state.
- 5) The number of personnel engaged in radiation work and exposure doses have been collected since the institution of control zones.
- 6) The exposure dose of personnel who worked at both the Tokai Power Station and the Tokai Daini Power Station of the Japan Atomic Power Company Co., Ltd., was calculated by dividing the value that was indicated on the film badge into proportions based on the dosimeter of the thermo luminescence dosimeters at these two plants.

- (3) Regarding occupational radiation exposure, the Occupational Exposure Central Registration Center of the Radiation Effects Association has registered and managed the data of occupational exposure doses, etc., in a centralized manner since November 1977, and has promoted the Radiation Work Passport System, thereby advancing the management of occupational radiation exposure.

As of the end of March 1989 there was the enrollment of 231,418 people with the issuance of 185,401 copies of the *Radiation Work Passport*.