

Status of Gaseous and Liquid Waste Management

① Commercial Power Reactor Facilities

Power station		Radioactive gaseous waste		Radioactivity
		Noble gas (Bq)	Iodine [¹³¹ I] (Bq)	Radioactive liquid waste (excluding ³ H) (Bq)
Japan Atomic Power Company Co., Ltd Tokai Power Station	*1 Nuclear reactor facilities total	N.D.	N.D.	5 2.3×10
	Annual release Target control level	-	-	7 7.4×10
Japan Atomic Power Company Co., Ltd. Tokai Daini Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release Target control level	15 1.4×10	10 5.9×10	10 3.7×10
Japan Atomic Power Company Co., Ltd. Tsuruga Power Station	Nuclear reactor facilities total	8 9.1×10	N.D.	N.D.
	Annual release Target control level	15 1.7×10	10 3.8×10	10 7.4×10
Tohoku Electric Power Co., Inc. Onagawa Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release Target control level	15 3.8×10	11 1.3×10	10 1.1×10
Tokyo Electric Power Co., Inc. Fukushima Daiichi Nuclear Power Station	Nuclear reactor facilities total	8 1.7×10	5 2.3×10	N.D.
	Annual release Target control level	15 8.8×10	11 4.8×10	11 2.2×10
Tokyo Electric Power Co., Inc. Fukushima Daini Nuclear Power Station	Nuclear reactor facilities total	10 3.4×10	N.D.	N.D.
	Annual release Target control level	15 5.5×10	11 2.3×10	11 1.4×10
Tokyo Electric Power Co., Inc. Kashiwazaki-Kariwa Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release Target control level	15 6.7×10	11 2.3×10	11 2.5×10
Chubu Electric Power Co., Inc. Hamaoka Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release Target control level	15 5.1×10	11 2.9×10	11 1.4×10
Hokuriku Electric Power Co. Shika Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release Target control level	15 1.1×10	10 3.0×10	10 3.7×10
Chugoku Electric Power Co., Inc. Shimane Nuclear Power Station	Nuclear reactor facilities total	N.D.	N.D.	N.D.
	Annual release Target control level	15 2.5×10	11 1.3×10	10 7.4×10

*1: Due to the commencement of the decommissioning process on December 4, 2001, ⁶⁰Co, ¹³⁴Cs and ¹³⁷Cs are the subjects of the annual release control targets for radioactive liquid waste.

Power station		Radioactive gaseous waste		Radioactivity Radioactive liquid waste (excluding ³ H) (Bq)
		Noble gas (Bq)	Iodine [¹³¹ I] (Bq)	
Hokkaido Electric Power Co., Inc. Tomari Power Station	Nuclear reactor facilities total	⁹ 4.5×10	N.D.	N.D.
	Annual release Target control level	¹⁵ 1.1×10	¹⁰ 1.1×10	¹⁰ 7.4×10
Kansai Electric Power Co., Inc. Mihama Power Station	Nuclear reactor facilities total	¹⁰ 1.1×10	⁵ 3.8×10	N.D.
	Annual release Target control level	¹⁵ 2.1×10	¹⁰ 7.4×10	¹¹ 1.1×10
Kansai Electric Power Co., Inc. Takahama Power Station	Nuclear reactor facilities total	¹⁰ 1.2×10	⁵ 3.4×10	N.D.
	Annual release Target control level	¹⁵ 3.3×10	¹⁰ 6.2×10	¹¹ 1.4×10
Kansai Electric Power Co., Inc. Ohi Power Station	Nuclear reactor facilities total	¹⁰ 2.8×10	N.D.	N.D.
	Annual release Target control level	¹⁵ 3.7×10	¹¹ 1.0×10	¹¹ 1.4×10
Shikoku Electric Power Co., Inc. Ikata Power Station	Nuclear reactor facilities total	⁹ 4.2×10	N.D.	N.D.
	Annual release Target control level	¹⁵ 1.5×10	¹⁰ 8.1×10	¹¹ 1.1×10
Kyushu Electric Power Co., Inc. Genkai Nuclear Power Station	Nuclear reactor facilities total	¹⁰ 1.2×10	N.D.	N.D.
	Annual release Target control level	¹⁵ 2.2×10	¹⁰ 5.9×10	¹¹ 1.4×10
Kyushu Electric Power Co., Inc. Sendai Nuclear Power Station	Nuclear reactor facilities total	¹⁰ 1.6×10	N.D.	N.D.
	Annual release Target control level	¹⁵ 1.6×10	¹⁰ 6.2×10	¹⁰ 7.4×10

Notes: The radioactivity (Bq) of gaseous (or liquid) waste is obtained by multiplying the concentration of the radioactive material (Bq/cm³) in the released gas (or liquid) by the amount of released gas (or liquid) (m³). Values lower than the detection limit of radioactivity are indicated as N.D.

The detection limits are as follows.

Radioactive noble gases: 2×10^{-2} (Bq/cm³) or less

Radioactive iodine: 7×10^{-9} (Bq/cm³) or less

Radioactive liquid waste (excluding ³H): 2×10^{-2} (Bq/cm³) or less (the ⁶⁰Co value is used)