

**Table 1 Status of Radioactive Gaseous Waste Release Management in FY2014**  
(Nuclear Reactor Facilities for Test and Research, etc.)

[Unit: Bq]

| Site Name  | Facility (measurement location)                    | Item                              | Annual Release Control Target | Annual Release#2           |                 |
|--|--|-----------------------------------|-------------------------------|----------------------------|-----------------|
| Japan Atomic Energy Agency   | Nuclear Science Research Institute                 | JRR-2                             | Tritium                       | 2.4E+11                    | N.D. (N.D.)     |
|  |  | JRR-3 *1                          | Radioactive Noble Gases       | 6.2E+13                    | N.D. (N.D.)     |
|  |  |                                   | Tritium                       | 7.4E+12                    | N.D. (N.D.)     |
|  |  | JRR-4 *1                          | Radioactive Noble Gases       | 9.6E+11                    | N.D. (N.D.)     |
|  |  | NSRR *1                           | Radioactive Noble Gases       | 4.4E+13                    | 1.2E+8 (4.6E+9) |
|  |  |                                   | Iodine 131                    | 4.8E+09                    | N.D. (N.D.)     |
|  |  | TCA                               | Iodine 131                    | #1                         | N.D.<br>(N.D.)  |
|  |  | FCA *1                            | Iodine 131                    | #1                         | N.D.<br>(N.D.)  |
|  | STACY<br>TRACY *1                                  | Radioactive Noble Gases           | 8.1E+13                       | N.D. (N.D.)                |                 |
|  |  | Iodine 131                        | 1.5E+10                       | N.D. (N.D.)                |                 |
|  | Oarai Research and Development Center (North Area) | JMTR *1                           | Radioactive Noble Gases       | 1.3E+14                    | N.D. (N.D.)     |
|  |  |                                   | Radioactive Noble Gases       | 3.7E+13                    | N.D. (N.D.)     |
|  |  | HTTR *1                           | Iodine 131                    | 3.2E+09                    | N.D. (N.D.)     |
|  |  |                                   | Tritium                       | 1.1E+13                    | N.D. (N.D.)     |
|  | Oarai Research and Development Center (South Area) | Deuterium Critical Assembly (DCA) | Radioactive Noble Gases       | #1                         | N.D.<br>(N.D.)  |
|  |  | Experimental Fast Reactor Joyo    | Radioactive Noble Gases       | 3.4E+13                    | N.D. (N.D.)     |
| Aomori Research and Development Center, Mutsu Office                                 | First Nuclear Ship                                 | Dust                              | #1                            | N.D.<br>(N.D.)             |                 |
| The University of Tokyo, Graduate School of Engineering, Nuclear Professional School | Reactor of the University of Tokyo (Yayoi)         | Radioactive Noble Gases           | #1                            | No release<br>(No release) |                 |
| Kyoto University, Research Reactor Institute   | KUR *1   | Radioactive Noble Gases           | 4.0E+13                       | 8.6E+10 (1.0E+11)          |                 |
|  | KUCA *1  | Radioactive Noble Gases           | #1                            | N.D.<br>(N.D.)             |                 |
| Rikkyo University, Institute for Atomic Energy                                       | Rikkyo University Reactor                          | Dust                              | #1                            | 5.6E+4 (4.6E+5)            |                 |
| Tokyo City University, Atomic Energy Research Institute                              | Musashi Institute of Technology Research Reactor   | Dust                              | #1                            | N.D.<br>(N.D.)             |                 |
| Kinki University, Atomic Energy Research Institute                                   | Kinki University Reactor                           | Radioactive Noble Gases           | #1                            | N.D.<br>(N.D.)             |                 |
| Toshiba Corporation  | Research Reactor Center                            | TTR-1                             | Dust                          | #1<br>(N.D.)               |                 |
|  | Nuclear Engineering Laboratory                     | NCA                               | Radioactive Noble Gases       | #1<br>(N.D.)               |                 |
| Hitachi, Ltd., Ozenji Hitachi Training Reactor Center                                | HTR  | Dust                              | #1                            | No release<br>(No release) |                 |

\*1: Radioactive gaseous waste from the Nuclear Science Research Institute, Japan Atomic Energy Agency (JAEA), the JAEA Oarai Research and Development Center (North Area), and the Research Reactor Institute, Kyoto University includes radioactive gaseous waste from nuclear fuel material use facilities.

\*2: Due to a revision to the operational safety program, Rikkyo University discontinued measurement of noble gases in January 2005, and Tokyo City University discontinued measurement of noble gases in August 2007.

\*3: At Rikkyo University, the annual release control target is a combined value that also includes the value for nuclear fuel material use facilities.

(Note) This table has been prepared as follows.

(1) #1: Reactor facility for test and research, etc. for which no annual release control target has been stipulated.

(2) #2: Values in parentheses ( ) indicate actual values from the previous fiscal year.

(3) N.D.: Not Detected - values under the detection limit

(Table expression example) "E-3" indicates " $\times 10^{-3}$ ."

**Table 2 Status of Radioactive Liquid Waste Release Management in FY2014  
(Nuclear Reactor Facilities for Test and Research, etc.)**

[Unit: Bq]

| Site Name  |  | Item               | Annual Release Control Target | Annual Release#2        |    |
|--|--|--------------------|-------------------------------|-------------------------|----|
| Japan Atomic Energy Agency   | Nuclear Science Research Institute                   | Other than Tritium | 1.8E+10                       | 5.5E+6 (1.4E+7) *6      | *1 |
|  |  | Cobalt 60          | 3.7E+09                       | N.D. (2.7E+5)           |    |
|  |  | Cesium 137         | 3.7E+09                       | 4.5E+6 (1.3E+7) *6      |    |
|  |  | Tritium            | 2.5E+13                       | 5.4E+10 (1.9E+11)       |    |
|  | Oarai Research and Development Center (North Area)   | Other than Tritium | 2.2E+09                       | N.D. (N.D.)             | *2 |
|  |  | Cobalt 60          | 2.2E+08                       | N.D. (N.D.)             |    |
|  |  | Cesium 137         | 1.8E+09                       | N.D. (N.D.)             |    |
|  |  | Tritium            | 3.7E+12                       | 2.0E+6 (1.1E+6)         |    |
|  | Oarai Research and Development Center (South Area)   | Other than tritium | 3.7E+08                       | N.D. (N.D.)             | *3 |
|  | Aomori Research and Development Center, Mutsu Office | Other than Tritium | 1.1E+08                       | No release (no release) |    |
| The University of Tokyo, Graduate School of Engineering, Nuclear Professional School | Other than Tritium                                   | #1                 | 1.1E+04<br>(N.D.)             |                         |    |
| Kyoto University, Research Reactor Institute   | Other than Tritium                                   | #1                 | N.D.<br>(N.D.)                |                         |    |
| Rikkyo University, Institute for Atomic Energy                                       | Other than Tritium (Cobalt 60 equivalent)            | -                  | - (4.3E+3)                    | *4                      |    |
| Tokyo City University, Atomic Energy Research Laboratory                             | Other than Tritium                                   | -                  | - (-)                         | *5                      |    |
| Kinki University, Atomic Energy Research Institute                                   | Other than Tritium                                   | 3.7E+07            | 1.5E+3 (2.8E+3)               |                         |    |
| Toshiba Corporation  | Research Reactor Center                              | Other than Tritium | 3.7E+06                       | N.D. (N.D.)             |    |
|  | Nuclear Engineering Laboratory                       | Other than Tritium | 3.7E+06                       | N.D. (N.D.)             |    |
| Hitachi, Ltd., Ozenji Hitachi Training Reactor Center                                | Other than Tritium                                   | #1                 | No release<br>(No release)    |                         |    |

- \*1: The Nuclear Science Research Institute, Japan Atomic Energy Agency (JAEA) accepts radioactive liquid waste generated at nearby nuclear sites in addition to processing such waste generated at locations other than reactor facilities.
- \*2: In the JAEA Oarai Research and Development Center (North Area), radioactive liquid waste generated at facilities other than HTTR facilities is transferred to the Oarai Research and Development Center's radioactive waste storage facility, and is thus not included in this table.
- \*3: In the JAEA Oarai Research and Development Center (South Area), radioactive liquid waste is transferred to the Oarai Research and Development Center's radioactive waste storage facility, and is thus not included in this table.
- \*4: At Rikkyo University, the operational safety program was revised with the progress of decommissioning (approved on February 7, 2014), and measurement was discontinued. Before that, the annual release control target was a combined value that also covered the value for nuclear fuel material use facilities.
- \*5: Use of disposal equipment for liquid waste was suspended based on the February 25, 2010 approval of an alteration to the decommissioning plan. The equipment was then disassembled and removed based on the September 16, 2011 approval of an alteration to the decommissioning plan.
- \*6: Due to the effects of discharge of radioactive materials caused by the accident at TEPCO's Fukushima Daiichi NPS.

(Note) This table has been prepared as follows.

- (1) #1: Reactor facility for test and research, etc. for which no annual release control target has been stipulated.
- (2) #2: Values in parentheses ( ) indicate actual values from the previous fiscal year.
- (3) N.D.: Not Detected - values under the detection limit

(Table expression example) "E-3" indicates " $\times 10^{-3}$ ."